

2021 Consumer Confidence Report



Roger Kramer

Operator

3455 N Old US Hwy 421

Greensburg, IN. 47240

Office: 812-663-3119

www.decatourcountyruralwater.com

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is purchased from the City of Greensburg, which is treated surface water from the Flat Rock River, northwest of the City of Greensburg. Greensburg also uses a ground water source from six wells in the City of Greensburg.

We're very pleased to report that our drinking water is safe and meets Federal and State requirements. If you have any questions regarding this report or concerning your water utility, please contact Roger Kramer at 812.663.3119, by, e-mail at dcrw.operator@gmail.com. We want our valued customers to be informed about their water utility. If you would like to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday of the month at 5:00 PM at the water office, which is located 3455 N Old US Hwy 421, in Greensburg.

Decatur County Rural Water Corporation routinely monitors for constituents in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2021 All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

All sources of drinking water are subject to potential contamination by constituents that are natural occurring or manmade. Those constituents can be micro, organic, or inorganic chemicals, or radioactive materials.

The sources of drinking water (both tap and bottled water) include river, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or throughout the ground, it dissolves naturally occurring minerals and, in some cases, radioactive can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic system, agricultural livestock operation and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agricultural, storm water runoff, and residential areas.
- Organic chemicals, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also, come from gas stations, urban storm water runoff, and residential uses.
- Radioactive materials, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. More information about contaminants and potential health effects can be obtained by calling the **Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as individuals with cancer undergoing chemotherapy, those who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These individuals

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions.

- **Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.
- **Parts per billion (ppb) or Micrograms per liter** – one part per billion corresponds to one minute in 2,000 years or a single penny in &10,000,000.
- **Nephelometric Turbidity unit (NPU)** – nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- **Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **Treatment Technique (TT)** – A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.
- **Maximum Contaminant Level (MCL)**– (mandatory language) The “Maximum Allowed” (MCL) is the highest level of a contaminant that is allowed in drinking water. MCL’s are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Contaminant Level Goal (MCLG)** – (mandatory language) The “Goal” (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Residual Disinfectant Level (MRDL)** – The highest level of a disinfectant allowed in drinking water.
- **Maximum Residual Disinfectant Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health.

<u>Decatur County Rural Water</u>		<u>TEST RESULTS</u>			<u>PWSID 5216008</u>	
Contaminant (units)	Range	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<u>INORGANIC CONTAMINANTS</u>						
Copper 90TH % Value		0.110	ppm	1.3	1.3 (AL)	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing
Lead 90th % Value	6.6	1.7	ppb	15	15 (AL)	Corrosion of household plumbing; Erosion of natural deposits
<u>DISINFECTION BYPRODUCTS</u>						
Haloacetic Acids (HAA5)	25.0 to 123.0	AVG 49.5	ppb	None	60	By-product of drinking water chlorination
Total Trihalomethanes	35.9 to 111	AVG 67.2	ppb	None	80	Naturally present in the environment
<u>Violations 2nd Quarter 2021 & 3rd Quarter 2021 exceeded locational running annual average (LRAA)</u>						
1. Total Trihalomethanes (TTHM) Levels of Trihalomethanes (TTHM) above drinking water standards.						
Haloacetic Acids (HAA5) Levels of Haloacetic Acids (HAA5) above drinking water standards.						

Some people who drink **Trihalomethane & Haloacetic Acids (HAA5)** in excess of the MCL over many years may experience problems with their liver, kidney or central nervous system and may have an increased risk of getting cancer.

2. Monitoring Routine (MINOR)

TOTAL COLIFORM 12/1/2021 Failed to complete all required tests of our drinking water for the contaminant and period.

Atrazine

Some people who drink water containing Atrazine well in excess of MCL over many years could

Experience problems with their cardiovascular system or reproductive difficulties.

GREENSBURG WATER WORKS

TEST RESULTS

PWSID 5216002

Contaminant (units)	Range	Level Detected	Unit Measurement	MCLG	M CL	Likely Source of Contamination
<u>MICROBIOLOGICAL CONTAMINANTS</u>						
Turbidity	.02 to.29	Yearly Avg. 0.12	NTU	N/A	TT = 0.5	Soil runoff
Highest single measurement= 0.29. All of our samples were below the turbidity limits specified for our filtration technology. Turbidity is measured to determine the clarity of the water after filtration. It is used to determine whether small particles that could cause disease are able to get through our treatment process and into the water system.						
<u>INORGANIC CONTAMINANTS</u>						
Copper	<0.005 TO 0.518	90% value 0.104	Ppm	1.3	AL= 1.3	Corrosion of household plumbing systems, erosion of natural deposites ; leaching from wood preservatives
Fluoride	02 To 1.5	Yearly Avg. 0.6	Ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as Nitrogen)	2021	0.14	Ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

HM (Total Trihalomethanes)	24.3 TO 188	AVG. 72.3	ppb	N/A	80	By-product of drinking water chlorination
Cholorine	2021	1	1-1	4	pp m	Water additive used to control microbes
HAA5's (Total Haloacetic Acids)	12.6 TO 131	AVG 45.9	ppb	N/A	60	By-product of drinking water chlorination
Total Organic Carbon	0 TO 1.8	AVG. 1.1	ppb	N/A	>1. 0 An nua l Avg .	By-product of drinking water chlorination

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Synthetic organic contaminants including Pesticides and herbicides	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Atrazine	2021	0.3	0-0.3	3	3	ppb	N	Runoff from Herbicide used on row crop
2,4,D	2021	2.2	0-2.2	70	70	ppb	N	Herbicide runoff
Xylenes	2021	0.0006	0- 0.0006	10	10	pp m	N	

UNREGULATED CONTAMINANTS

Contami nants (units)	Range	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Sodium	2021	18.7	ppm	None	None	Consumer Information

Water Hardness	2021	19 gpg	gpg			Moderately Soft-Consumer Information
----------------	------	--------	-----	--	--	--------------------------------------

Violations

1. Monitoring, Routine (minor) date 4/02021 – 6/30/2021 Failed to complete all of required tests of our drinking water for the contaminant and period.

Alachlor

Some people who drink water containing Alachlor in excess of MCL over many years couldHave problems with their eyes, liver, kidneys o

2. Monitoring, Routine, (MINOR) Date 4/01/2021-6/30/2021 failed to complete all of required

Atrazine

Some people who drink water containing **Atrazine** well in excess of MCL over many years could Experience problems with their cardiovascular system or reproductive difficulties.

3. Monitoring, Routine, (MINOR) Date 4/01/2021-6/30/2021 failed to complete all of required Test of our drinking water for contaminant and period.

Di (2- ethylhexyl) adipate

Some people who drink water containing **Di(ethylhexyl) adipate** well in excess of MCL over many years could Experience problems general toxic effects or reproductive difficulties.

4. Monitoring, Routine (minor) Date 4/01/2021-6/30/2021

Di (2-ethylhexyl) phthalate

Some people who drink water containing **di(2-ethylhexyl) phthalate** well in excess of MCL over many years could experience general toxic effects or reproductive difficulties.

Simazine

5. Monitoring, Routine (minor) Date 4/01/2021-6/30/2021, Failed to complete all the required tests of our drinking water for the contaminate and period.

Some people who drink water containing **Simazine** in excess of MCL over many years could Experience problems with their blood.

6.Total Trihalomethane (TTHM)

MCL,LRAA 7/01/2021-9/30/2021 Water samples showed that the amount of this contaminant in our drinking water was above standards.

Some people who drink water containing **Trihalomethanes** in excess of MCL over many years may experience problems with their liver, kidneys, or central nervous systems and may have an increased risk of getting cancer.